



1B230K1 Test Manual

Two Shot Auto Reclose Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual



Relay Software



µMATRIXwin



1B230K1 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1b230.pdf>
- User Guide: http://www.rmspl.com.au/userguide/1b230_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/1b230_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/1b230acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	05/10/2000	Released.
B	28/04/2004	Document reformat

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	

1.0 HARDWARE SPECIFICATIONS – 1B230K01 [B][B][A][C][C][C][C][C]

- 1.1 Auxiliary Supply**
Auxiliary Supply Voltage [B] 40 - 300 VDC
- 1.2 Counter**
[B] Fitted
- 1.3 Series Initiate Input**
[A] Not required
- 1.4 Status Input 4**
CB Auxiliary Switch [C] 75 - 150 V AC/DC
- 1.5 Status Input 5**
Drive To Lockout + Reset Lockout [C] 75 - 150 V AC/DC
- 1.6 Status Input 6**
Line Volt Monitor [C] 75 - 150 V AC/DC
- 1.7 Status Input 7**
Spring Charge + Safe To Close [C] 75 - 150 V AC/DC
- 1.8 Status Input 8**
Main Protection Shunt [C] 75 - 150 V AC/DC
- 1.9 Non-Standard Features**
Hardware specifications not described in Data Sheet. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 151-230-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

