

Order Number

Serial Number

PRODUCT/TEST MANUAL

1L71K2

POWER SUPPLY & TRANSMIT RELAY

Issue Level	Date	Summary of changes
A	9/07/01	Initial issue.

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
AF	MW	MW	

7. GENERAL & FUNCTIONAL

- a) Check that unit operates satisfactorily over the range of 216 to 264 volts auxiliary supply.
- b) Ensure contacts operate correctly
- c) Check that the relay is electrically sound and mechanically robust as per Standard Inspection & Test Schedule 903-000-026

PASS

TESTED BY : _____ DATE : _____

8. CONNECTION DIAGRAM

