




# 1S25K4 Test Manual

## Arc Fault Monitor

relay monitoring systems Pty Ltd

---

Advanced Protection Devices



# 1S25K4 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1s25.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1s25\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1s25_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1s25\\_application.pdf](http://www.rmspl.com.au/solutions/1s25_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1s25acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	04/10/2011	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	



**1.0 HARDWARE SPECIFICATIONS – 1S025K04 [B][#][S]**

**1.1 Auxiliary Supply**

[B] 40 – 275 VAC, 40 – 300VDC

**1.2 Custom Engraved Text**

[#] Specified at order

**1.3 Non-Standard Features**

Hardware specifications not described in Technical Bulletin.

Code [S] = Segregated outputs

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 198-025-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

### 3.0 CONNECTION DIAGRAM

