



# *1S26K4 Test Manual*

## *Arc Fault Monitor & Current Check*

relay monitoring systems pty ltd

### **Advanced Protection Devices**



User Guide

Test Manual

# 1S26K4 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1s26.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1s26\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1s26_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1s26\\_application.pdf](http://www.rmspl.com.au/solutions/1s26_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1s26acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	07/11/2008	Released.
B	26/05/2010	Sensor Inputs where grounded CR0951

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	



**1.0 HARDWARE SPECIFICATIONS – 1S026K04 [B][B][A][#]**

- 1.1 Auxiliary Supply** [B] 40 – 275VAC, 40-300VDC
- 1.2 Current Setting** [B] 20-200% A&C, 5-50% E/F
- 1.3 Auxiliary Supply** [A] 1A
- 1.4 Custom Engraved Text** [#] Specified at order
- 1.5 Non-Standard Features**  
Hardware specifications not described in Technical Bulletin. None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 198-026-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

**3.0 CONNECTION DIAGRAM**

