




# *1S26K7 Test Manual*

## *Arc Fault Monitor & Current Check*

relay monitoring systems pty ltd

---

### **Advanced Protection Devices**



User Guide



Test Manual



# 1S26K7 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1s26.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1s26\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1s26_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1s26\\_application.pdf](http://www.rmspl.com.au/solutions/1s26_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1s26acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	01/10/2009	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	



**1.0 HARDWARE SPECIFICATIONS – 1S026K07 [A][A][B][#][S]**

**1.1 Auxiliary Supply**

[A] 20 – 70VDC

**1.2 Current Setting**

[A] 20-200% all phases

**1.3 Auxiliary Supply**

[B] 5A

**1.4 Custom Engraved Text**

[#] Specified at order

**1.5 Non-Standard Features**

Hardware specifications not described in Technical Bulletin. [S]  
Segregated output relay board 660/378-1 is used in this version.  
Refer to wiring diagram.

**NOTE TO TEST. CONFIG SWITCH C2 MUST BE SET TO OFF BEFORE SHIPPING.**

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 198-026-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

