




1X30 Test Manual

Trip Circuit Supervision Scheme

Advanced Protection Devices



User Guide



Test Manual



Test Manual

Links to Other Documents

<http://www.rmspl.com.au/spdl/1x30.htm>

Test Certification

Made in Australia by Relay Monitoring Systems Pty Ltd.

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	08/06/2006	Initial issue.
B	22/06/2009	Code was BBB

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	

1.0 HARDWARE SPECIFICATIONS – 1X030K80 [B][B][A]**1.1 Supervision Voltage**

[B] 32VDC

1.2 Supervision Scheme

[B] Green LED. Normal = ON

1.3 Custom Front Panel Label

[A] Not required.

1.4 Non-Standard Features

Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 156-030-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

