



Test Manual

Instantaneous Current Check Relay

Advanced Protection Devices



User Guide



Test Manual

Test Manual

Links to Other Documents

<http://www.rmspl.com.au/spdl/2c64.htm>

Test Certification

Made in Australia by Relay Monitoring Systems Pty Ltd.
This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	09/06/2005	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	

1.0 HARDWARE SPECIFICATIONS – 2C064K80 [A][B][B][A][A]

- 1.1 **Auxiliary Supply** [A] 20 - 70VDC
- 1.2 **Current Setting** [B] 20 – 200%
- 1.3 **CT Input Rating** [B] 5Amp Nom
- 1.4 **Customer Specified Output Contacts** [A] 3c/o 3Ø Instantaneous
- 1.5 **Relay Initiate Option** [A] Always enabled
- 1.6 **Non-Standard Features**
Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 159-064-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

