



2C65K5 Test Manual

Definite Time Current Check Relay

relay monitoring systems Pty Ltd

Advanced Protection Devices



User Guide



Test Manual





2C065K5 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2C65.pdf>
- User Guide: http://www.rmspl.com.au/userguide/2C65_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/2C65_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/2C65acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	11/10/2007	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



1.0 HARDWARE SPECIFICATIONS – 2C065K05 [B][B][A][B][S]

1.1 Auxiliary Supply

[B] 40 - 275 VAC, 40 - 300 VDC

1.2 Current Setting

[B] 20 - 200%

1.3 CT Rating

[A] 1 Amp

1.4 Timing Function

[B] Definite Time Delay – LED Indication

1.5 Non-Standard Features

Hardware specifications not described in Technical Bulletin. [S]

- 1) Firmware for Powerlink.
- 2) Status input voltage p.u. to 80V.

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 159-065-805 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

