



# *2C137K7 Test Manual*

## *Sensitive Earth Fault Relay*

relay monitoring systems pty ltd

---

### **Advanced Protection Devices**



User Guide



Test Manual



# 2C137K7 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2C137.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/2C137\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/2C137_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/2C137\\_application.pdf](http://www.rmspl.com.au/solutions/2C137_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/2C137acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	02/11/2000	Initial issue.
B	30/11/2007	Updated to micro controller version

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
CLM	DG	DG	

**1.0 HARDWARE SPECIFICATIONS – 2C137K07 [B][B][C][E][A]**

<b>1.1 Auxiliary Supply</b>	[B]	40 - 275 VAC, 40 - 300 VDC
<b>1.2 CT Input Rating</b>	[B]	5 Amp Nom
<b>1.3 Initiate Input</b>	[C]	150 - 300 V AC-DC
<b>1.4 Remote Flag Reset Input</b>	[E]	24VDC
<b>1.5 Timing Reset Function</b>	[A]	Instantaneous Reset
<b>1.6 Non-Standard Features</b> Hardware specifications not described in Technical Bulletin.		None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 159-137-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

### 3.0 CONNECTION DIAGRAM

