

169-033-991
Issue C 01/02/95
Sheet 1 of 5



Order Number

Serial Number

2H33D110 TEST PROCEDURE

DEFINITE TIME UNDER FREQUENCY RELAY

1. TEST EQUIPMENT REQUIRED

- 110 Volt DC Supply
- 110 Volt AC Supply
- Digital Frequency Meter
- Digital Voltmeter
- Digital Storage Oscilloscope

2. ASSOCIATED DRAWINGS

- 169-033-291 Master Circuit Diagram
- 660-099-301 PCB Loading - Analogue Section
- 660-100-301 PCB Loading - Digital Section
- 660-129-301 PCB Loading - Thumbwheel Switch Mtg.

3. HIGH VOLTAGE TESTING

Apply 2KV RMS. between the terminal groups as listed in A & B below for 1 minute.

<u>GROUP A</u>	<u>GROUP B</u>	
3,4,8,9	0,1,2,5,7	OK
0,3,5,8	1,2,4,7,9	<input type="checkbox"/>
0,1,2,3,4,5,7,8,9	FRAME	

4. CALIBRATION & TEST PROCEDURE

4.1 Disassembly Procedure

To gain access to the non component sides of the analogue and digital circuit boards, the relevant shield boards must be removed. After removing the four side covers, the front and back plates should be removed (there are four lots of four screws). This enables the desired board/rail assembly to be unplugged from the thumbwheel mounting PCB. Care should be exercised during this step to avoid damaging the Ferranti flag mechanism.

4.2 Undervoltage Lockout Calibration

- a) Apply auxiliary supply of 82 volts and check that 10 volt and 20 volt rail voltages are within +/- 10 percent of nominal.
- b) Monitoring test point 2 on the 660-099 PCB adjust trimpot R18 until the voltage just goes low when the AC voltage is reduced below 55 volts. (The filter switch should be in the "OUT" position).
- c) Check that test point 2 switches cleanly as the AC voltage is increased above approximately 65 volts .

4.3 Bandpass Filter Operation

- a) Connect a dB (decibel) measuring DVM between IC-1 pin 8 and the +10 volt rail.
- b) Check that for 110 volts AC in maximum amplitude on the DVM occurs within the range of 45-50 Hz.

OK

- c) Check that at 30 Hz and 60 Hz that IC1-8 is more than 7db below amplitude at resonance.

4.4 Oscillator 1 Mhz

Connect a frequency counter to TP3 on PCB 660-100 and check that the frequency is within +/- 50 Hz of 1 Mhz.

OK



4.5 Frequency Measuring Clock Circuitry

- a) Connect the oscilloscope to TP4 and trigger input to IC3 pin 2. (set trigger on the -ve going edge).
- b) Set “period setting to 20.00 ms, “time” to 0.05 S and “cycles to reset” DIL switch to 4 cycles.
- c) Set AC input period to 20.01 ms and check that TP4 waveform is as shown on sheet 18 of the descriptive manual. Note that the observed waveform will jitter due to the non synchronism of AC input and clock waveforms. This waveform is best observed by storing a single sweep on a storage oscilloscope.
- d) Adjust the input period to 19.90ms and check that the three or four “hysteresis” pulses disappear for the overfrequency condition. (output relay dropped out)

4.6 Period Setting Thumbwheel Switches

- a) For the following settings record the input waveform period at which the output relay operates. Adjust frequency downwards (increasing period) to ensure that the hysteresis does not influence the results. Perform the tests at nominal AC and DC voltage levels.
- b) Settings

<u>SETTING</u>	<u>MINIMUM</u>	<u>MAXIMUM</u>	<u>NOMINAL</u>	<u>ACTUAL</u>	<u>UNITS</u>
11.11	11.10	11.12	11.11		ms
12.22	12.21	12.23	12.22		ms
13.33	13.32	13.34	13.33		ms
14.44	14.43	14.45	14.44		ms
15.55	15.54	15.56	15.55		ms
16.66	16.65	16.67	16.66		ms
17.77	17.76	17.78	17.77		ms
18.88	18.87	18.89	18.88		ms
19.99	19.98	20.20	19.99		ms
20.00	19.99	20.01	20.00		ms



4.7 Timer Logic Check

Check that when the underfrequency condition is present a 10 ms period waveform appears at TP6 on 660-100 logic PCB.

OK

4.8 Timer Operational Check

- a) Adjust input frequency to 80Hz (12.5ms period) and set period setting to 10.00ms. Set AC & DC input voltages levels to nominal. Connect timing apparatus "power" contacts between 660-100 SK1 pins 6 & 24. When the contact is closed the 2H33 will effectively be set at 14.00ms and when open the setting will be 10.00ms as indicated.
- b) Measure the time interval between the opening of the "power" contact and the operation of the output relay contact. Note that the observed times will be 30 - 40 ms greater than the timer settings due to the operate time of the output relay and the response time of the frequency sensing circuitry.
- c) Record times for the following time settings.

<u>SETTING</u>	<u>MINIMUM</u>	<u>MAXIMUM</u>	<u>NOMINAL</u>	<u>ACTUAL</u>	<u>UNIT</u>
0.11	0.12	0.16	0.14		SEC
1.22	1.23	1.27	1.25		SEC
2.33	2.34	2.38	2.36		SEC
3.44	3.45	3.49	3.47		SEC
4.55	4.56	4.60	4.58		SEC
5.66	5.67	5.71	5.69		SEC
6.77	6.78	6.82	6.80		SEC
7.88	7.89	7.93	7.91		SEC
8.99	9.00	9.04	9.02		SEC
9.00	9.01	9.05	9.03.		SEC

4.9 Cycles To Reset Timer

- a) Adjust input frequency to 50 Hz and set period setting to 15 ms. Set timer to 1.00 sec. Connect "power" contact of the timing apparatus

between R25 - D11 junction and SK1 pin 27 (on 660-100 PCB). The number of cycles to reset the timer will be the time interval between closure of the "power" contact and the dropout of the out put relay.



169-033-991
 Issue C 01/02/95
 Sheet 5 of 5

4.9 Cycles to Reset Timer (Cont)

b) Set "cycles to reset" DIL switch to 0111 (7 cycles) and record the time.

<u>MINIMUM</u>	<u>MAXIMUM</u>	<u>NOMINAL</u>	<u>ACTUAL</u>	<u>UNIT</u>
160	195	175	<input type="text"/>	ms

c) Set "cycles to reset "DIL switch to 1000 (8 cycles) and record time.

<u>MINIMUM</u>	<u>MAXIMUM</u>	<u>NOMINAL</u>	<u>ACTUAL</u>	<u>UNIT</u>
180	215	195	<input type="text"/>	ms

5. GENERAL & FUNCTIONAL

Check that the relay is electrically sound and mechanically robust as per Standard Inspection & Test Schedule 903-000-026

PASS

TESTED BY : _____ DATE : _____