



2P48 Test Manual

Potential Selecting Relay

relay monitoring systems pty ltd

Advanced Protection Devices



2P48 depicted in a 4M28 case



2P48 Test Manual

Links to Other Documents

Technical Bulletin: <http://www.rmspl.com.au/2p48.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Job Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	.
A	25/11/2013	Initial issue.

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked	PDF file created	Registered & Released
MVL	SG	SG	



1.0 ORDER CODE DEFINITION

The order code definition is described below and highlighted for the products manufactured with the Job Number shown on page 1.

2P48				Potential Selecting Relay
Sensing Supply	A			110V 50Hz
	C			110V 60Hz
Time Delay		A		2s delay on drop off
		B		Not required
		C		5s delay on drop off
		D		10s delay on drop off
		E		2s delay on pick up
		F		5s delay on pick up
		G		10s delay on pick up
		H		2s delay on pick up & drop off
		I		5s delay on pick up & drop off
		J		10s delay on pick up & drop off
Magnetic Blowouts			A	Required
			B	Not required

2.0 VERIFICATION


This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 162-048-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE



3.0 CONNECTION DIAGRAM



2P48 wiring diagram