



2SY112K10 Test Manual

Synchronism Check Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual





2SY112K10 Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/2sy112_user_guide.pdf

Test Certification

Made in Australia

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	22/02/2010	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DHW	DG	



1.0 HARDWARE SPECIFICATIONS – 2SY112K10 [B][C][C][S]

1.1 Auxiliary Supply

[B] 40 - 275 VAC, 40 - 300 VDC

1.2 Group 1 Status Inputs

[C] 150 – 300V

1.3 Remote Reset

[C] 150 – 300V

1.4 Non-Standard Features

Hardware specifications not described in Technical Bulletin.

[S] Bus & Line volts = 400/230VAC

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 171-112-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

