

DDB20(K83) Test Manual

Multi Range Precision Time Delay Relay

relay monitoring systems pty ltd

Advanced Protection Devices




User Guide



Test Manual





DDB20(K83) Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2T104.pdf>
- User Guide: http://www.rmspl.com.au/userguide/2T104_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/2T104_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/2T104acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number


Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	07/06/2005	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



1.0 HARDWARE SPECIFICATIONS – DDB20(K83) [B][G][G][A][S]

1.1 Auxiliary Supply

Auxiliary Supply Voltage [B] 40-300VDC , 40-275VAC

1.2 Timing Initiate Input

[G] 110VDC

1.3 Remote Flag Reset Input

[G] 110VDC

1.4 Timing Reset Function

[A] Instantaneous Reset

1.5 Non-Standard Features

Hardware specifications not described in Technical Bulletin. [S] 4C/O Contacts

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 164-104-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

