

2T645K6 Test Manual

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

| Order Number | Serial Number |
|--------------|---------------|
| | |

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

| Issue | Date | Summary of changes |
|-------|------------|--------------------|
| H | 06/04/2005 | Document reformat |
| | | |
| | | |
| | | |

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

| Author | Checked & Registered | .pdf file created | Released |
|--------|----------------------|-------------------|----------|
| ERL | DG | DG | |

1.0 HARDWARE SPECIFICATIONS – 2T645K6

| | |
|-----------------------------|-----------------------------------|
| 1.1 Auxiliary Supply | 110 VDC |
| 1.2 Timing Range | .5 – 127.5 Seconds |
| 1.3 Contacts | 2 N/O Delayed, 2N/O Instantaneous |
| 1.4 Enclosure Type | VYT20 |
| 1.5 TfA | 60798 |

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 164-645-800 and in accordance with the relevant International (IEC) Standards.

| PASSED BY | DATE |
|-----------|------|
| | |