

2T645K8 Test Manual

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
E	11/04/2008	Document reformat

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
MVL	DG	DG	

1.0 HARDWARE SPECIFICATIONS – 2T645K8

- 1.1 Auxiliary Supply** 110 VDC
- 1.2 Timing Range** .005 – 1.275 Seconds
- 1.3 Contacts** 2 N/O Delayed, 2N/O Instantaneous
- 1.4 Enclosure Type** FNDY20
- 1.5 TfA** 153122

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 164-645-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE