



2V164K7 Test Manual

Voltage Regulating & Control Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual



Relay Software



µMATRIXwin



2V164K7 Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/2V164_user_guide.pdf

Software Downloads: <http://www.rmspl.com.au/digital/uMATRIX.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Factory Loaded UMX	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	10/12/2002	Initial issue.
B	29/05/2003	Verification procedure revised
C	27/06/2003	Document facelift
D	29/04/2005	Document reformat

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ARF	DG	DG	



1.0 HARDWARE SPECIFICATIONS – 2V164K07 [B][C][C][B]

1.1 Auxiliary Supply

Auxiliary Supply Voltage [B] 40 - 275 VAC, 40 - 300 VDC

1.2 Digital Input Operating Voltage – Group 1

Status Inputs Group 1 [C] 150 – 300V AC-DC

1.3 Digital Input Operating Voltage – Group 2

Status Inputs Group 2 [C] 150 - 300 V AC-DC

1.4 Analogue Outputs

[B] Fitted

1.5 Non-Standard Features

Hardware specifications not described in Data Sheet. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 165-164-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE