



2V164

Test Manual

Voltage Regulating & Control Relay

Advanced Protection Devices



User Guide



Test Manual



Relay Software



µMATRIXwin



Test Manual

Links to Other Documents

<http://www.rmspl.com.au/spdl/2v164.htm>

Test Certification

Made in Australia by Relay Monitoring Systems Pty Ltd.
This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Factory Loaded UMX	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	12/07/2005	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ARF	DG	DG	

1.0 HARDWARE SPECIFICATIONS – 2V164K80 [B][C][C][B]

- 1.1 Auxiliary Supply**
Auxiliary Supply Voltage [B] 40 - 275 VAC, 40 - 300 VDC
- 1.2 Digital Input Operating Voltage – Group 1**
Status Inputs Group 1 [C] 150 – 300V AC-DC
- 1.3 Digital Input Operating Voltage – Group 2**
Status Inputs Group 2 [C] 150 - 300 V AC-DC
- 1.4 Analogue Outputs**
[B] Fitted
- 1.5 Non-Standard Features**
Hardware specifications not described in Data Sheet. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 165-164-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE