



2V165-SK6 Test Manual

Transformer Parallel Control Relay

relay monitoring systems Pty Ltd

Advanced Protection Devices



User Guide



Test Manual



Relay Software



MATRIXwin



2V165-SK6 Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/2v165-s_user_guide.pdf

Software Downloads: <http://www.rmspl.com.au/digital/umatrix.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

| Order Number | Factory Loaded UMX | Serial Number |
|--------------|--------------------|---------------|
| | | |

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

| Issue | Date | Summary of changes |
|-------|------------|--------------------|
| A | 11/08/2009 | Initial issue. |
| | | |
| | | |
| | | |

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

| Author | Checked & Registered | .pdf file created | Released |
|--------|----------------------|-------------------|----------|
| DG | DHW | DG | |



1.0 HARDWARE SPECIFICATIONS – 2V165SK06 [A][D][D][D][B][B]

1.1 Auxiliary Supply

Auxiliary Supply Voltage [A] 20 - 70 VDC

1.2 Digital Input Operating Voltage – Group 1

Status Inputs Group 1 [D] 18 – 275VAC 300VDC

1.3 Digital Input Operating Voltage – Group 2

Status Inputs Group 2 [D] 18 - 275VAC 300VDC

1.4 Digital Input Operating Voltage – Group 3

Status Inputs Group 3 [D] 18 - 275VAC 300VDC

1.5 Analogue Outputs

[B] 4 – 20mA Output

1.6 Rear Communications Port

[B] Modbus Protocol

1.7 Non-Standard Features

Hardware specifications not described in Data Sheet. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 165-165S-800 and in accordance with the relevant International (IEC) Standards.

| PASSED BY | DATE |
|-----------|------|
| | |