165-550-901 Issue A 8/05/01 Sheet 1 of 4



PRODUCT/TEST MANUAL

2V550K1

VOLTAGE SENSING RELAY

Order Number

Serial Number

Issue	Date	Summary of changes
A	8/05/01	Initial issue.

Due to RMS continuous product improvement policy this information is subject to change without notice. This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	MW	MW	

165-550-901 Issue A 8/05/01 Sheet 2 of 4



1. BROAD DESCRIPTION OF RELAY

The 2V550K1 is a voltage sensing relay which measures the voltage drop across a shunt and is calibrated in Amps. The contacts of the voltage sensing element are fed to a 1 - 10 second timer which is in turn connected to the out 6R relay. The output relay is a heavy duty 6R element with latched contacts and flag.

2. SPECIFICATIONS

DC SENSING VOLTAGE	40 - 60 mV
SETTING SCALE	1000 – 2000 Amps
SETTING ACCURACY	+/- 10% of setting
AMBIENT TEMPERATURE RANGE	-5 to 55 ⁰ c

3. TEST EQUIPMENT REQUIRED

Auxiliary DC Power Supply Digital Voltmeter Decade Box High Voltage Test Equipment

4. ASSOCIATED DRAWINGS

165-550-101	Wiring Diagram
690-013-250	Circuit Diagram
690-013-350	Loading Diagram
165-550-701	Front Label

5. HIGH VOLTAGE TESTING

- a) Apply 2KV RMS between the terminal groups as listed in A & B below for 1 minute.
- b) Apply three 5KV 1/50usec pulses of each polarity as listed in A & B below.

<u>GROUP A</u>

<u>GROUP B</u>

All terminals

Frame

165-550-901 Issue A 8/05/01 Sheet 3 of 4

7.



6. CALIBRATION AND TEST PROCEDURE

6.1 Voltage Sensing

a) Calibrate the voltage sensing PCB as per instruction sheet 165-731-900 using the 30 – 60 volt adjustment procedure.

		PASS				
6.3	Timing Checks					
a)	Set the timer to minimum scale (1 second) set the current calibrated setting PU dial scale (1500 Amps) and apply 60 mV to terminals 1 & 3 and check that the output re operates after the 1 second delay.					
		Pass				
b)	Repeat (a) with the timer set to maximum scale (10 seconds)					
		Pass				
GENE	RAL & FUNCTIONAL					
a)	Check for correct operation of mechanical flag	g.				
b)	Check that the relay is electrically sound and mechanically robust as per Standard Inspection & Test Schedule 903-000-026					
		PASS				

TESTED BY :______DATE :_____

165-550-901 Issue A 8/05/01 Sheet 4 of 4



8. CONNECTION DIAGRAM

