




2V630K15 Test Manual

Single Pole AC Voltage Relay

relay monitoring systems pty ltd

Advanced Protection Devices



 User Guide

 Test Manual

2V630K15 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2V63.pdf>
- User Guide: http://www.rmspl.com.au/userguide/2V63_user_guide.pdf
- Application: <http://www.rmspl.com.au>
- Acad Case Drawings: <http://www.rmspl.com.au/2V63acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	16/11/2006	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



1.0 HARDWARE SPECIFICATIONS – 2V630K15 [C][A][A][C][A]

- 1.2 Voltage Pick Up Range** [C] 75 – 150VAC
- 1.3 Case Configuration** [A] One Element – 2M28
- 1.4 Output Contacts** [A] 6R std duty
- 1.5 Reset Flag** [C] Hand Reset, Operate on D.O.
- 1.6 Pick Up and Drop Out Configuration** [A] D.O. Adjustable – P.U. Fixed (96VAC)
- 1.7 Non-Standard Features**
Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 162-630-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

