




2V631K8 Test Manual

Single Pole DC Voltage Relay

Relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual

2V631K8 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2V63.pdf>
- User Guide: http://www.rmspl.com.au/userguide/2V63_user_guide.pdf
- Application: <http://www.rmspl.com.au>
- Acad Case Drawings: <http://www.rmspl.com.au/2V63acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	23/09/2008	Released.
B	04/07/2013	Update to order code

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked	PDF file created	Registered & Released
MVL	SG	SG	



1.0 HARDWARE SPECIFICATIONS – 2V631K08 [H][A][A][C][A]

- 1.2 Voltage Pick Up Range** [H] 75 – 150VDC
- 1.3 Case Configuration** [A] One Element – 2M28
- 1.4 Output Contacts** [A] 6R heavy duty
- 1.5 Reset Flag** [C] Hand Reset, Operate on D.O.
- 1.6 Pick Up and Drop Out Configuration** [A] D.O. Adjustable – P.U. Fixed
- 1.7 Non-Standard Features**
Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 162-631-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

