



3A300K7 Test Manual

Pilot Wire DC Intertrip & Supervision

Advanced Protection Devices



User Guide



Test Manual



3A300K7 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/3A300.pdf>
- User Guide: http://www.rmspl.com.au/userguide/3A300_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/3A300_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/3A300acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	14/05/2007	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	ERL	ERL	



1.0 HARDWARE SPECIFICATIONS – 3A300K07 [B][A][B][A]

- 1.1 Auxiliary Supply** [B] 70 - 150VDC
- 1.2 Pilot Wire Insulation** [A] 5kV RMS
- 1.3 Remote Reset Status Input** [B] 75 – 150V AC/DC
- 1.4 Mounting** [A] 4U rack or Flush
- 1.5 Non-Standard Features**
Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 172-300-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

