



4M320K5 Test Manual

Test Plug

relay monitoring systems Pty Ltd

Advanced Protection Devices



Test Manual



4M320K5 Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/4m320_user_guide.pdf

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	25/05/2010	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DHW	DHW	DG	



1.0 HARDWARE SPECIFICATIONS – 4M320K5 [S][B]

1.1 Auxiliary Supply Isolating Link

[S] Terminals 17-19, 21-23, 25-27
Bridged internally.

1.2 Case Length

[B] Long

1.3 Non-Standard Features

Hardware specifications not described in Data Sheet. .

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 195-300-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

