



# 4M400-S-[22892212228889]- Test Manual Test Block System

relay monitoring systems Pty Ltd

---

Advanced Protection Devices





4M400-S-[22892212228889]-

# Test Manual

## Links to Other Documents

---

User Guide: [http://www.rmspl.com.au/userguide/4m400\\_4m420\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/4m400_4m420_user_guide.pdf)

## Test Certification

---

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

| Order Number | Serial Number |
|--------------|---------------|
|              |               |

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

---

| Issue | Date       | Summary of changes |
|-------|------------|--------------------|
| A     | 12/03/2015 | Initial issue.     |
|       |            |                    |
|       |            |                    |

Due to RMS continuous product improvement policy this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

| Author | Checked | PDF File Created | Registered & Released |
|--------|---------|------------------|-----------------------|
| MVL    | SG      | SG               |                       |



**1.0 HARDWARE SPECIFICATIONS – 4M400-S-[22892212228889]-**

**1.1 CT Shorting Bars (case):**  
5-7, 21-23-25-27

**1.2 Front Cover Isolation Link:**  
13-14

**1.3 Isolation Links (test block):**  
1-2,3-4,5-6,7-8,9-10,11-12,15-16,17-18,19-20,21-22,23-24,25-26,27-28.

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 195-400-800 and in accordance with the relevant International (IEC) Standards.

| PASSED BY | DATE |
|-----------|------|
|           |      |