



# 4M400-S-[22222218918889]- Test Manual Test Block System

relay monitoring systems Pty Ltd

---

Advanced Protection Devices





4M400-S-[22222218918889]-

# Test Manual

## Links to Other Documents

---

User Guide: [http://www.rmspl.com.au/userguide/4m400\\_4m420\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/4m400_4m420_user_guide.pdf)

## Test Certification

---

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

---

Issue	Date	Summary of changes
A	12/03/2015	Initial issue.

Due to RMS continuous product improvement policy this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked	PDF File Created	Registered & Released
MVL	SG	SG	



**1.0 HARDWARE SPECIFICATIONS – 4M400-S-[22222218918889]-**

**1.1 CT Shorting Bars (case):**

15-17, 21-23-25-27

**1.2 Front Cover Isolation Link:**

13-14, 19-20

**1.3 Isolation Links (test block):**

1-2, 3-4, 5-6, 7-8, 9-10, 11-12, 15-16, 17-18, 21-22, 23-24, 25-26, 27-28.

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 195-400-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE