



4M400-S-[88891888918889]- Test Manual Test Block System

relay monitoring systems Pty Ltd

Advanced Protection Devices





4M400-S-[88891888918889]-

Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/4m400_4m420_user_guide.pdf

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

| Order Number | Serial Number |
|--------------|---------------|
| | |

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

| Issue | Date | Summary of changes |
|-------|------------|--------------------|
| A | 12/03/2015 | Initial issue. |
| | | |
| | | |

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

| Author | Checked | PDF File Created | Registered & Released |
|--------|---------|------------------|-----------------------|
| MVL | SG | SG | |



1.0 HARDWARE SPECIFICATIONS – 4M400-S-[88891888918889]-

1.1 CT Shorting Bars (case):
1-3-5-7, 11-13-15-17, 21-23-25-27

1.2 Front Cover Isolation Link:
9-10, 19-20

1.3 Isolation Links (test block):
1-2, 3-4, 5-6, 7-8, 11-12, 13-14, 15-16, 17-18, 21-22, 23-24, 25-26, 27-28.

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 195-400-800 and in accordance with the relevant International (IEC) Standards.

| PASSED BY | DATE |
|-----------|------|
| | |