



4M402K20 Test Manual

Test Block System

relay monitoring systems pty ltd

Advanced Protection Devices





4M402K20 Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/4m400_4m420_user_guide.pdf

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

| Order Number | Serial Number |
|--------------|---------------|
| | |

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

| Issue | Date | Summary of changes |
|-------|----------|--------------------|
| A | 21/02/14 | Initial issue. |
| | | |
| | | |
| | | |
| | | |

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

| Author | Checked | PDF File Created | Registered & Released |
|--------|---------|------------------|-----------------------|
| MVL | SG | SG | |



1.0 HARDWARE SPECIFICATIONS – 4M402- S - [88898912898889]

1.1 CT Shorting Bars (case):

Group A and B: 1-3-5-7, 9-11, 17-19, 21-23-25-27

1.2 Front Cover Isolation Link:

Group A and B: 13-14

1.3 Isolation Links (test block):

Group A and B: 1-2,3-4,5-6,7-8,9-10,11-12,15-16,17-18,19-20,21-22,23-24,25-26,27-28

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 195-402-800 and in accordance with the relevant International (IEC) Standards.

| PASSED BY | DATE |
|-----------|------|
| | |