



6RJ14-10 Test Manual

Low Burden High Speed Trip Relay

relay monitoring systems pty ltd

Advanced Protection Devices





6RJ14-10 Test Manual

Links to Other Documents

Technical Bulletin: <http://www.rmspl.com.au/handbook/6rj14.pdf>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Job Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	19/08/2014	Initial issue.

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked	.PDF file created	Registered & Released
MVL	SG	SG	



1.0 ORDER CODE DEFINITION

The order code definition is described below and highlighted for the products manufactured with the Job Number shown on page 1.

6RJ14 -	10			High Speed Trip Relay
				Electrical reset contacts / Hand reset flag

Number of Contacts	10	10 contacts
Nominal Operate Voltage	A	24 V dc
	B	32 V dc
	C	48 V dc
	D	110 V dc
	E	125 V dc
	G	220 V dc
	H	240 V dc
	F	250 V dc

Contact Arrangement	xM xB	Specify the number of "MAKES" followed by M Specify the number of "BREAKS" followed by B
---------------------	-------	---------------------------------------------------------------------------------------------

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 173-506-80x and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM – 10 CONTACTS

The connection diagram with job number is attached.