



ABM Test Manual

Active Burden Module

relay monitoring systems Pty Ltd

Advanced Protection Devices





ABM Test Manual

Links to Other Documents

Technical Bulletin: <http://www.rmspl.com.au/abm.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Job Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	24/10/2013	Initial issue

Due to RMS continuous product improvement policy this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked	.PDF file created	Registered & Released
MVL	SG	SG	



1.0 ORDER CODE DEFINITION

The order code definition is described below and highlighted for the products manufactured with the Job Number shown on page 1.

ABM					Active Burden Module
Elements per case	-				Standard ABM
	Z				Standard ABM with input voltage threshold
Nominal Auxiliary Voltage		C			48 / 54V DC
		D			110 / 125V DC
		F			220 / 250V DC
Termination Style (ABM) / Threshold Voltage (ABMZ)			1		Flying Leads (ABM)
			2		Screw Terminals (ABM)
			30V		30V DC (ABMZ)
			80V		80V DC (ABMZ)
			150V		150V DC (ABMZ)
Non-standard Parameters				-	Details: None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 199-100-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE